

**ADDENDUM TO THE FACT SHEET
FOR MODIFICATION OF
STATE WASTE DISCHARGE PERMIT ST-7427
DOW JONES & COMPANY (THE WALL STREET JOURNAL)**

January 16, 2004

The Department is proposing to issue a modification of State Waste Discharge Permit ST-7427. The permit was issued on October 15, 2003. The proposed modification consists of changing the discharge limitation for silver in the permit from 0.2 mg/L to 2.0 mg/L. This modification is necessary due to a technical error made during the drafting of the permit. The silver discharge limitation of 0.2 mg/L was based on local discharge limitations established by the Lakehaven Utility District. The compliance point for the 0.2 mg/L limitation is defined by Lakehaven Utility District as the final point where such wastewaters are discharged to the sanitary sewer. The compliance point in the existing permit is the discharge of the industrial wastewater silver pretreatment facility, prior to the introduction of any non-silver bearing wastewaters. Due to the significant amount of non-silver bearing domestic, and non-silver bearing industrial wastewaters at this plant, compliance with a silver discharge limitation of 2.0 mg/L immediately following the pretreatment system is expected to result in compliance with the Lakehaven Utility District limitation of 0.2 mg/L. The proposed limitation of 2.0 mg/L is based on AKART (All Known Available and Reasonable Methods of Prevention Control and Treatment) as required under WAC 173-216-110.